

RJM Corporation
Ten Roberts Lane
Ridgefield, CT 06877
203 438-6198

**FACSIMILE TRANSMITTAL COVER SHEET**DATE: 6/20/91

FAX NO.: _____

Please deliver the following pages to:

COMPANY: Intermountain Power NAME: Garon NissenREFERENCE: Pg. No. 915332THIS FAX IS FROM: Richard MonroeNumber of pages 2 (including cover sheet) transmitting from Xerox 7032 (Telephone 203-431-8255)**MESSAGE:**

As requested, attached is a partial list
of RJM's clients for your reference

RJM

If you do not receive all of the pages - please call 203-438-6198 as soon as possible.

IP7_005106

(216) 880 1967
 Peter Wanders B&W
 Burner Section
 RJM LaRoc

RJM CORPORATION

SELECTIVE CLIENT REFERENCE LIST

Burner Consultants :

Abtech Engr.
 Sunnyville,
 California
 (408) 745-7000
 Terry Hertzig

infinite e-burnt
 analysis

NLS Testing - Canada (B&W)

Mr. Vic Nichols
 Manager of Production Performance
 Public Service Company of Oklahoma
 918-599-2927-2546

gas fired units
 B&W (not their problem)

4-24% Balancing RJM
 Sinker

Air Quality

4895 #3.3451

Mr. Manny Robledo
 Design Mechanical Engineer
 Los Angeles Department of Water & Power
 213-481-4750

Air Quality
 Cause + Planning

7/15/91
 Haynes 3
 Closed Flow Analysis
 wrap-around / over-free air
 flow analysis + balancing
 referal B&W
 design change - gas recirc

Griffith Broadwick RJM
 VP Fuel Tech

SoCal Ed:

(818) 302-1212

(818) 302-7261

Mr. Juan Cordova
 Plant Engineer
 El Paso Electric
 915-543-5837

Mr. Bill Million
 Plant Manager

Oklahoma Gas & Electric Company
 405-789-7858

89

Mandakly Steam Station

- Angel Alvaras

Project Manager (Paul Sutherland)

7/15/91

natural gas

S. Burrows Huntington Beach
 flue gas recirc

RJM temp profile:

slow monitoring analytical results
 burner balancing - W&B

Ray Eichner Orland Beach
 flow monitoring

UREA injection

Mike Fattigatti
 Peter Wanders

Mr. Howard Mellvaine
 Director of Engineering
 Atlantic Electric Company
 609-625-6567

modal time
 1st coal - next spring
 other pay